


Test Verification of Conformity

Verification Number: 180802442SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Shanghai Yongji Electrical Co., Ltd. No.2239, South Jinshi Road., Jinshanwei Town, Jinshan District, Shanghai, P.R.China
Manufacturing Site Name & Address:	Jovean & Rogy Electrical Holding Co., Ltd. of Wenzhou No.132, Xinguang Road, Xinguang Industrial Zone, Liushi Town, Yueqing Cit Zhejiang Province, P.R.China Zhejiang Yongji Electrical Co., Ltd. No.788, Nanming Road, Lishui Economic and Technological Development Z Lishui City Zhejiang Province, P.R.China
Product Description:	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)
Ratings & Principle Characteristics:	Un= 240V~(1P+N), 415V~(3P+N), 50/60Hz In= 25, 32, 40, 63A IΔn= 0,03; 0,1; 0,3A; Type A and AC, IΔc = Inc = 10000A
Models/Type References:	JVL16-63
Brand Name(s):	
Standard(s)/Directive(s):	EN61543: 1995/+A11: 2003/+A12: 2005/+A2:2006 The EMC Directive 2014/30/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Test Report Number(s):	180802442SHA-001



Oliver Wei
Manager
November 3 2018