



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA191572

Date of Issue: 14 June 2019

Class Description: Non-Declared
Product Description: Connecting device
(Terminal block with cable gland)

Additional Models	Trade Name	Rating	Description
EW-M20-4P	E-WeiChat	400Vac/dc 24A	Wire Section: 0.5-2.5mm ² Outer Cable Dia: 8-10.5mm Poles: 4
EW-M25-4P	E-WeiChat	400Vac/dc 41A	Wire Section: 1.5-6.0mm ² Outer Cable Dia: 11-14mm Poles: 4
EW-M25-5P	E-WeiChat	400Vac/dc 24A	Wire Section: 0.5-2.5mm ² Outer Cable Dia: 11-14mm Poles: 5
EW-M20T-4P	E-WeiChat	400Vac/dc 24A	Wire Section: 0.5-2.5mm ² Outer Cable Dia: 8-10.5mm Poles: 4
EW-L03	E-WeiChat	400Vac/dc 24A	Wire Section: 0.5-2.5mm ² Outer Cable Dia: 8-10.5 mm Poles: 3
EW-M16-2P	E-WeiChat	400Vac/dc 17.5A	Wire Section: 0.5-1.5mm ² Outer Cable Dia: 7-10mm Poles: 2

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 28-06-19 191572/2a
Ratings corrected